

SOLUTIONS MANUAL FOR

**Electric Power
Distribution Engineering**

THIRD EDITION

_____ by _____

Turan Gönen



CRC Press
Taylor & Francis Group

SOLUTIONS MANUAL FOR

Electric Power
Distribution Engineering
THIRD EDITION

_____ by _____

Turan Gönen



CRC Press

Taylor & Francis Group

Boca Raton London New York

CRC Press is an imprint of the
Taylor & Francis Group, an **informa** business

2-16

$$D_g = \frac{\left(\sum_{i=1}^{12} TCD_i \right) \times DF_i}{F_D} = \frac{\sum_{i=1}^{12} (20 \text{ kW} \times 0.6)}{1.15} = \frac{12 \times 20 \times 0.6}{1.15} = 125.2 \text{ kW}$$

2-17

(a)

$$\text{Annual } P_{\text{avg}} = \frac{100,000,000 \text{ kWh/yr}}{8760 \text{ h/yr}} = 11,415.5 \text{ kW}$$

or

$$\text{Monthly energy} = \frac{100,000,000 \text{ kWh/yr}}{12 \text{ mos/yr}} = 8,333,333.3 \text{ kWh}$$

$$\text{Avg. monthly demand} = \frac{8,333,333.3 \text{ kWh}}{730 \text{ h/mo}} = 11,415.5 \text{ kW}$$

$$F_{LD} = \frac{\text{Ann. avg. load}}{\text{Peak monthly demand}}$$

$$(b) \text{ Max. monthly demand} = \frac{\text{Ann. avg. load}}{F_{LD}} = \frac{11,415.5 \text{ kW}}{0.6} \cong 19,026 \text{ kW}$$

Note that, max means peak here.

2-18

(a)

$$D_{FD} = \frac{900 + 1000 + 2100 + 2000}{D_g} = 1.25 \Rightarrow D_g = \frac{6,000}{1.25} = 4,800 \text{ kW} = P$$

$$PF_1 = \cos \theta_1 = 0.85 \Rightarrow \theta_1 = 31.79^\circ$$

$$PF_2 = \cos \theta_2 = 0.9 \Rightarrow \theta_2 = 25.84^\circ$$

$$PF_3 = \cos \theta_3 = 0.95 \Rightarrow \theta_3 = 18.2^\circ$$

$$PF_4 = \cos \theta_4 = 0.9 \Rightarrow \theta_4 = 25.84^\circ$$

$$Q = \frac{\sum_{i=1}^4 P_i \times \tan \theta_i}{F_D} = \frac{900 \tan 31.79^\circ + 1000 \tan 25.84^\circ + 2100 \tan 18.2^\circ + 2000 \tan 25.84^\circ}{1.25}$$

$$= \frac{2,701.09}{1.25} \cong 2,160.87 \text{ kvar}$$

$$S = (P^2 + Q^2)^{1/2} = (4800^2 + 2,160.87^2)^{1/2} \cong 5,264 \text{ kVA which is also } D_g \text{ in kVA}$$

$$(b) LD = \sum_{i=1}^4 D_i - D_g = 6000 - 4,800 = 1,200 \text{ kW}$$

$$(c) \text{ Since } (4687 \text{ kVA})1.25 = 5,858.75 \text{ kVA} > 5,264 \text{ kVA}$$

choose 3750/4687 kVA transformer.